

TEST PROGRAM: TEST UNDER SPECIFIED LOAD

Objective:

The aim of this test is to simulate battery performance by running a set of user-defined load until battery reached specified end of discharge voltage. The end of discharge voltage, load and time can be set as required by customers in volts, amperes and minutes. This test is particularly useful to determine the battery performance under stressful heavy load continuously.

Procedure and Standard:

The battery is fully charged. The next step is to discharge the battery to specified end of discharge voltage by customer. If not specific requirements are provided by customers, MI will help customers to choose the values within battery maximum ratings according to battery datasheet. After discharging, the battery is fully charge again. The total capacity calculated from discharging is assessed to determine the real capacity of battery. The whole testing can be repeated as required. The duration of testing time is listed as below at default charge and discharge rates.

NiCd/NiMH: 2.5-10 Hours SLA: 20-40 Hours Li-ion/LiFePO4: 6-20 Hours

Equipment:

1. Cadex Analyser - C7x00s and C8000

Voltage: 1.2V - 36V Current: 100mA - 20A

Power: 35W - 100W (per station)

2. West Mountain Radio (WMR) CBA Analyser with 500W amplifier

Voltage: 0.9V - 55V Current: 45mA - 160A

Power: 500W

3. Vencon UBA

Voltage: 1.2V - 44V Current: 12mA - 3A Power: 45W (per channel)


Results:

The detail display (right) shows battery run-times as well as battery voltage, current and temperature.

In addition, test reports the duration of voltage, battery capacity in AH. The real capacity from testing is shown as percentage of the rated capacity of battery in the report of Cadex Analysers.

See test report samples as below

- 1. Cadex Test Report
- 2. CBA Test Report
- 3. UBA Test Report





Sydney: (02) 9519 1200 Perth: (08) 9302 5444 Melbourne: (0 Brisbane: (0

(03) 9872 6422 (07) 3387 7711 EMAIL: sales@master-instruments.com.au WEB: www.master-instruments.com.au



TEST PROGRAM: TEST UNDER SPECIFIED LOAD

Sample Report 1: CADEX C7

BatteryShop Report Master Instruments

2/1/2016 7:03:16 AM

Battery Information

Battery ID: N/A
Battery manufacturer: BANKSYS ATOS
Battery model: 3032610137
Used in: Payment Terminals
Customer: Sample Company

Service Information

Service ID: 20943 Port/Station number: 10/2 (7450ER/1.1) Start date: 1/29/2016 7:02:11 AM End date: 1/29/2016 1:30:18 PM 0:6:28:7 [dd:hh:mm:ss] **Duration:** Charge cycles: Discharge cycles: 1 Recondition cycles: 0 Station program: Auto Target capacity: 80%

Battery Status

 Capacity:
 94%, 94%

 State-of-health:
 N/A

 OhmTest:
 313 mOhms

 Test result:
 PASS

 Fault code:
 N/A

Battery Parameters

Battery chemistry: LiPh Nominal voltage: 3.30 Volts Battery rating: 600 mAh Charge rate: 360 mA Discharge rate: 120 mA Capacity offset: 0% Temperature sensing: 5C - 45C Max. charge voltage: 3.60V/Cell Standby voltage: 3.45V/Cell End of charge: 0.03C End of discharge: 2.00V/Cell

Service Notes

N/A

BatteryShop Report: 7.1.1.0.8 - C7400ER C-Series/1.1



Master Instruments Pty Ltd


 Sydney:
 (02) 9519 1200
 Melbourne:
 (03) 9872 6422
 EMAIL:
 sales@master-instruments.com.au

 Perth:
 (08) 9302 5444
 Brisbane:
 (07) 3387 7711
 WEB:
 www.master-instruments.com.au



TEST PROGRAM: TEST UNDER SPECIFIED LOAD

Sample Report 1: CADEX C7





Master Instruments Pty Ltd


Sydney: (02) 9519 1200 **Perth:** (08) 9302 5444

Melbourne: Brisbane: (03) 9872 6422 (07) 3387 7711 EMAIL: sales@master-instruments.com.au
WEB: www.master-instruments.com.au



TEST PROGRAM: TEST UNDER SPECIFIED LOAD

Sample Report 2: CBA



12SB50C:

Description: 6 Lead Acid cells, 50.0 Ah @ 20.00A

Started At: 27/01/2016 8:16 AM

Discharge Rate: 20.00 A Starting Voltage: 12.71 V Ending Voltage: 10.50 V

Internal Resistance: 0.05 Ohms Total Time (hh:mm:ss): 00:40:42 Tested Capacity: 13.566 Ah



TEST PROGRAM: **TEST UNDER SPECIFIED LOAD**

Sample Report 3: UBA



Battery Analysis Results

BAR: S:\USERDATA\JoshyP\Backup\UBA4_DATA\SLA 3 Cycle 2.5V Per Cell Charged.bar Filename: D:\Vencon\UBA4_DATA\6V 500mA SLA PS-605WL New Stock # 14.uba Serial number: 6875 Chan1

Number of cells: 3 Rated capacity: 500.0 mAh Start time: 2011-10-07 15:54

Summary: Capacity: 386.2mAh (77.2% rated). Fail. Capacity: 466.3mAh (93.3% rated). Pass. Capacity: 487.2mAh (97.4% rated). Pass.

SLA Discharge

Duration (h:m:s): 15:15:43
Load current: 25:36 mA
Cut-off voltage: 1.750 V
Battery discharged capacity: 386.2 mAh
Exit condition: Battery cut-off voltage reached

SLA Fast Charge
Duration (h:m:s): 01:45:48

Charge current: 200.0 mA
Battery charged capacity: 326.2 mAh Exit condition: Final charge current reached SLA Float Charge

Duration (h:m:s): 06:00:00 Charge current: 25.00 mA Battery charged capacity: 137.5 mAh Exit condition: Maximum time reached

Branching SLA Discharge

Duration (h:m:s): 18:24:50
Load current: 25.70 mA
Cut-off voltage: 1.750 V
Battery discharged capacity: 466.3 mAh
Exit condition: Battery cut-off voltage reached

SLA Fast Charge Duration (h:m:s): 01:59:19 Charge current: 200.0 mA Battery charged capacity: 401.3 mAh Exit condition: Final charge current reached SLA Float Charge

Duration (h:m:s): 06:00:00 Charge current: 25.00 mA
Battery charged capacity: 117.4 mAh Exit condition: Maximum time reached

Goto Branching

SLA Discharge
Duration (h:m:s): 19:14:00
Load current: 25.75 mA
Cut-off voltage: 1.750 V

Battery discharged capacity: 487.2 mAh
Exit condition: Battery cut-off voltage reached

SLA Fast Charge
Duration (h:m:s): 01:56:36 Charge current: 200.0 mA
Battery charged capacity: 396.9 mAh Exit condition: Final charge current reached

SLA Float Charge Duration (h:m:s): 06:00:00 25.00 mA Charge current: Battery charged capacity: 167.4 mAh Exit condition: Maximum time reached

Goto

Branching
Exit condition: Count 3 iterations



(02) 9519 1200 Melbourne: (03) 9872 6422 EMAIL: sales@master-instruments.com.au Perth: (08) 9302 5444 Brisbane: (07) 3387 7711 WEB: www.master-instruments.com.au